

HEAT

energy

HEAT energy Kft.
Erdész u. 28.
8800 Nagykanizsa,
Hungary

subject Conformity EKB Regulator
Email wendy.blumink@kiwa.com
date 19-09-2022
reference Performance testing P000122652 – LC21282

With this letter we hereby confirm Kiwa has tested your Household gas regulator EKB with a H2 Mixture of 20% and 100% in test report LC21282.

As referenced documents we used approval requirement 214:2019 and NEN 7239:2018 for the tests to carry out. The application of the EKB regulator is with an inlet pressure of 5 bar.

Kiwa has carried out the following tests which passed successfully:

- Internal leak tightness
- External leak tightness
- Long term behaviour
- Functionality

The results are outlined in test report LC21282 provided by Kiwa.

With kind regards

A handwritten signature in black ink, appearing to read "W.B.", with a horizontal line extending to the right.

Wendy Blumink
Certification Engineer
Appliances and Installations